


## ACTS-175 Specifications


<b>Basic Tower Construction Materials</b>	
Tower support frame assembly:	-
Casing:	FRP
Casing supporter:	Nylon
Cold water basin:	FRP
Filling:	PVC
Filling support:	PVC
Fan guard:	PP
Mechanical equipment support	HDGS
Air inlet louver:	PVC
<b>Structural Details</b>	
Overall diameter:	130 in
Overall height:	98 in
Dry weight:	1,569 lbs
Operating weight:	5,887 lbs
Total pump head:	11 ft
Design wind load:	30.7 lb/sq ft
<b>Fan Motor</b>	
Number of motors:	one unit per tower
Type:	Induction
Insulation:	CTS
Rated HP:	5 h. p.
Voltage and phase:	220/440-3

<b>Piping Connections</b>	
Primary water inlet diameter:	5 in
Primary water outlet diameter:	5 in
Auto fill inlet diameter:	1 in
Quick fill inlet diameter:	- in
Overflow outlet diameter:	2 in
Drain diameter:	2 in
<b>Design and Operating Conditions</b>	
Nominal Tons:	175
Tower type:	Counter Flow
Water flow rates:	369 gpm
Hot water temperature:	95° f
Cold water temperature:	85° f
Ambient wet bulb temperature:	75° f
Total fan BHP:	5 h. p.
Drift loss of water flow rates:	0.002%
Evaporation loss of water flow rates:	0.93%
<b>Mechanical Equipment</b>	
Fan unit:	one unit per
Type:	Axial Flow
Diameter:	69 in
Blade material:	AC
Hub material:	AC
Nominal air volume:	40,250 cfm

Assembly Diagram




# American Chillers & Cooling Tower Systems



Item No.	Description	Qty
1	Fan Motor	1 pcs
2	V-Belt Reducer	-
3	Motor Frame Assembly	1 set
4	Fan	1 set
5	Fan Guard	1 set
6	Casing	6 pcs
7	Hand Hole	1 pcs
8	Sprinkler Head	1 set
9	Sprinkler Pipe	4 pcs
10	Eliminator	4 pcs
11	Tension Device	4 set
12	Stand Pipe	1 set

Item No.	Description	Qty
13	Filling	1 set
14	Stopper or Column	1 set
15	Filling Supporter	1 set
16	Casing Supporter	6 pcs
17	Inlet Louver	1 set
18	Frame Assembly	-
19	Water Basin	5 pcs
20	Water Sump	1 pcs
21	Ladder	1 set
22	Strainer	1 pcs
23	Flange	2 pcs
24	Basin Supporter	-



Measurement	Distance (Inches)
D1	112.5
W	56.25
B	12
A	-
h	12
h1	13.5
C	16
D2	-
Anchor Bolt	
Size (In.)	Length (In.)
0.625	8